

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE OF PAGES 1   3	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 10-May-2002		4. REQUISITION/PURCHASE REQ. NO. W81G67-1236-3169		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING DIVISION USACE - ST PAUL 190 5TH STREET E ST PAUL MN 55101-1638		CODE DACW37		7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACW37-02-B-0011	
				X		9B. DATED (SEE ITEM 11) 18-Apr-2002	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.  Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D.OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  Contract Updates. Bid Opening Date remains May 21, 2002 at 1400 local time							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  10-May-2002	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

**1. CLAUSES****52.217-4000 OPTION FOR ADDITIONAL WORK (Construction) (AUG 2000)**

The Government may require the Contractor to perform the work identified as optional item(s) (CLIN(s) 0014 through 0232) at the price stated in the Schedule. The Contracting Officer may exercise the option(s) by written notice to the Contractor at any time before the required completion date stated in Section 00800, clause number 52.211-10 Alt 1, or any extensions thereto. The Contracting Officer shall provide the Contractor notice of the Government's intent to exercise the option at least 30 calendar days in advance of exercising the option. Notice of intent to exercise the option shall not constitute an exercise of the option and shall not bind the government to exercise the option. If the Government should exercise the option(s) within 60 calendar days of the required completion date or any extension thereto, the Government shall extend the required contract completion date to 60 calendar days after the date of the exercise of the option.

Exercise of the option shall be evidenced on Standard Form 30, citing this Section as the authority for exercising the option. Notice of intent to exercise the option shall be considered to have been given at the earlier of the occurrence of any of the following events: deposit of written notification in the mail, receipt by the Contractor of a facsimile notifying it of the Government's intent to exercise the option, or receipt by the Contractor of an e-mail notifying the Contractor of the Government's intent to exercise the option. The option shall be considered to have been exercised at the time the Government deposits written notification to the Contractor in the mail or, if earlier, at the time written notice is delivered to the Contractor.

It is expected that the optional bid items would be exercised within the following timeframes,"

<b><u>Option</u></b>	<b><u>Early Expectation Date</u></b>	<b><u>No Later Than Expectation Date</u></b>
Thorndale Area (CLIN 0014-0022)	22 Aug 2002	15 Sept 2002
Woods Addition (CLIN 0023-0098)	10 Aug 2002	15 Sept 2002
Ash Street (CLIN 0099-0148)	31 Jul 2002	15 Sept 2002
Summit Avenue (CLIN 0149 - 0203)	03 Aug 2002	15 Sept 2002
Elm Street Levee (CLIN 0204 - 0232)	10 Aug 2002	15 Sept 2002

The foregoing expected dates to exercise option(s) do not waive the Governments right to exercise any option(s) before or after that date.

**2. TECHNICAL**

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 2.3.3 (1), delete the last sentence, "Pumps shall be minimum 85% overall efficient at this condition point." And replace with the following sentences, "Efficiency shall be as defined by HI Standards. Pump bowl efficiency shall be minimum of 80% at 900 RPM pump speed."

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 2.3.13, between the first and second sentence, add additional sentence as follows: "Fabricated stainless steel shall be an acceptable alternate material for the impeller (propeller) and hub assembly."

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 2.5.3, At the end of the paragraph, add

additional sentences as follows, “Generally, the City will operate the gearbox and pump at 800 to 900 RPM input. However, the gearbox and pump may also be operated at speeds of 540 RPM. The gearbox shall be capable of operating at speeds from 540 RPM to 900 RPM.”

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 3.2.1, add additional sentences to the end of the paragraph as follows: "The pump and gearbox shall be assembled for the factory witness test. The Contractor shall be responsible for the design of the test set up to drive the gearbox. The test set up shall allow the gearbox to be driven at both 900 RPM and 540 RPM and allow for enough horsepower to operate the pump. The Contractor may factory test the remainder of the pumps required without the gearbox attached (non-witnessed testing) and at a single speed of 900 RPM.”

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 3.2.5, add additional sentence to the end of the paragraph as follows, "If the Contractor uses an alternate means of driving the gearbox (other than an electric motor), a method for determining horsepower shall be provided.”

Specification Section 15162, Tractor Driven Pumping Equipment, Paragraph 3.2.7, Before the first sentence, insert additional sentence as follows, “Provide a pump curve for all pumps at 900 RPM.” At the end of the paragraph, add sentences as follows, “For the witness test only, provide a second pump curve for a speed of 540 RPM. Use the same head condition points as the 900 RPM pump curve.”